



NOTES:

1. 2' COPPER OR BRONZE INLET OR OUTLET.
2. SUPPORT MEASURES MAY BE REQUIRED PARTICULARLY IF PVB IS HIGHER THAN 12" OFF GROUND.
3. PVB MUST BE INSTALLED 12" ABOVE HIGHEST IRRIGATION HEAD, MAX HEIGHT FOR INSTALLATION IS 5'.
4. FREEZE PROTECTION REQUIRED. APPROVED BRANDS ARE HOT BOX AND SAFE-T-COVER. NO SOFT BAG COVERS ARE ACCEPTED.

*TYPICAL PRESSURE VACUUM
BREAKER 1" THRU 2" BACKFLOW
PREVENTER ABOVE GROUND*

NOT TO SCALE

BERKELEY COUNTY WATER AND SANITATION
POTABLE WATER & SANITARY SEWER STANDARDS

REVISED 04/25/2023