



NOTES:

1. APPROPRIATE THRUST RESTRAINT AND SUPPORT MEASURES ARE TO BE DETERMINED BY OWNER/INSTALLER.
2. 4" OR GREATER BACKFLOW ASSEMBLY SHALL REQUIRE PIPE SUPPORT.

***DOUBLE CHECK VALVE TEMPORARY CONSTRUCTION
WATER METER AND BACKFLOW PREVENTION ASSEMBLY
ABOVE GROUND INSTALLATION***

NOT TO SCALE

BERKELEY COUNTY WATER AND SANITATION
POTABLE WATER & SANITARY SEWER STANDARDS
REVISED 05/15/20