



DEPTH SCHEDULE FOR HAUNCHING (GRAVITY LINE ONLY) AND BEDDING				
PIPE Ø	4"–10"	12"–18"	24"	36"
"A"	6"	8"	10"	12"
"B"	TO TOP OF PIPE		20"	27"

EMBEDMENT COMPACTION SHALL BE THE MINIMUM DENSITIES INDICATED IN TABLE 2 OF ASTM D2321-LR.

*FORCE MAIN/EFFLUENT/GRAVITY LINE*  
*TRENCH DETAIL*

NOT TO SCALE

**SEWER PANEL 4**

**BERKELEY COUNTY WATER AND SANITATION  
POTABLE WATER & SANITARY SEWER STANDARDS**

REVISED 04/25/2023