



- NOTES:
1. UNDER STORM DRAINAGE: USE STEEL CASING (X2 DIA.) IF LESS THAN 24" VERTICAL CLEARANCE. CASING MINIMUM LENGTH IS 10'.
 2. 18" VERTICAL CLEARANCE SHALL BE MAINTAINED BETWEEN ALL WATER & SEWER CROSSINGS
 3. ALL DIP FITTINGS USED ON FM SHALL BE INTERNALLY COATED WITH APPROVED EPOXY LINER.

*TYPICAL SEWER FORCEMAIN
DEFLECTION BELOW*

NOT TO SCALE

SEWER PANEL 4A

BERKELEY COUNTY WATER AND SANITATION
POTABLE WATER & SANITARY SEWER STANDARDS

REVISED 04/25/2023