



- NOTES:
1. 2' MIN. COPPER, DI, OR BRONZE INLET AND OUTLET
 2. CONCRETE SLAB STABILIZES SUPPORTS BETWEEN BACKFLOW AND GROUND SIZE ACCORDINGLY OR BY MANUFACTURERS' RECOMMENDATIONS.
 3. 4" OR GREATER BACKFLOW ASSEMBLIES SHALL REQUIRE PIPE SUPPORT.

NOTE:
 APPROPRIATE THRUST RESTRAINT AND SUPPORT MEASURES ARE TO BE DETERMINED BY OWNER/INSTALLER.

TYPICAL REDUCED PRESSURE PRINCIPLE ASSEMBLY
(ALL SIZES) BACKFLOW PREVENTION ASSEMBLY
ABOVE GROUND INSTALLATION

NOT TO SCALE