



NOTE:
 TEMPORARY BLOWOFF ASSEMBLY
 TO BE PERMANENT AFTER 2
 YEARS.

BLOWOFF ASSEMBLY
 NOT TO SCALE

WATER MAIN SIZE	TEMPORARY BLOWOFF PIPING SIZE	PERMANENT BLOWOFF PIPING SIZE
2"	2"	2"
4"	2"*	POST
6"	2"*	FIRE HYDRANT
8"	2 1/2"**	FIRE HYDRANT
10" OR GREATER	FIRE HYDRANT	FIRE HYDRANT

NOTE: ALL FIRE HYDRANTS SHALL HAVE A MINIMUM OF 500 GPM.
 * POST-TYPE HYDRANT MAY BE USED. MUST PROVIDE A MINIMUM OF 250 GPM.
 ** BCWS WILL PERMIT USE OF A POST-TYPE HYDRANT ON A CASE-BY-CASE BASIS.

WATER PANEL 5

**BERKELEY COUNTY WATER AND SANITATION
 POTABLE WATER & SANITARY SEWER STANDARDS**

REVISED 05/15/20