



NOTES:

1. PUMP STATION SITE SHALL BE GRADED SO AS TO ACHIEVE POSITIVE DRAINAGE AWAY FROM THE WETWELL.
2. PUMP STATION ACCESS ROAD SHALL BE A MINIMUM OF 16' WIDE WITH A 2% SLOPE TO PROVIDE POSITIVE DRAINAGE.
3. THE STABILITY OF THE SUBGRADE SHALL BE DEMONSTRATED BY PROOF ROLLING PRIOR TO PROCEEDING WITH CONSTRUCTION OF BASE OF PAVEMENT. PROOF ROLLING SHALL BE WITNESSED BY BCWS.

**ASPHALT SURFACE WITHIN
 PUMP STATION SITE
 AND ON ACCESS DRIVE**

NOT TO SCALE

SEWER PANEL 30